

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/04/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155502		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 10/02/2012	
NAME OF PROVIDER OR SUPPLIER TRANSCENDENT HEALTHCARE OF OWENSVILLE LLC				STREET ADDRESS, CITY, STATE, ZIP CODE HWY 165 W PO BOX 369 OWENSVILLE, IN 47665			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification, State Licensure, and Quality Assurance Walk-thru Survey conducted on 08/07/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 10/02/12</p> <p>Facility Number: 000328 Provider Number: 155502 AIM Number: 100287960</p> <p>Surveyor: Lex Brashear, Life Safety Code Specialist</p> <p>At this PSR survey, Transcendent Healthcare of Owensville, LLC was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, the 2000 edition of NFPA (National Fire Protection Association) 101, LSC (Life Safety Code) and 410 IAC 16.2. The original building was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (000) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and battery operated smoke detectors in all resident sleeping rooms. The facility has a capacity of 68 and had a census of 59 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/04/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155502		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 10/02/2012	
NAME OF PROVIDER OR SUPPLIER TRANSCENDENT HEALTHCARE OF OWENSVILLE LLC				STREET ADDRESS, CITY, STATE, ZIP CODE HWY 165 W PO BOX 369 OWENSVILLE, IN 47665			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
{K 000}	Continued From page 1 detector coverage. All areas where the residents have customary access were sprinklered and all areas providing facility services were sprinklered. Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 10/03/12.	{K 000}					
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification, State Licensure and Quality assurance Walk-thru Survey conducted on 08/07/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 10/02/12 Facility Number: 000328 Provider Number: 155502 AIM Number: 100287960 Surveyor: Lex Brashear, Life Safety Code Specialist At this PSR survey, Transcendent Healthcare of Owensville, LLC was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, the 2000 edition of NFPA (National Fire Protection Association) 101, LSC (Life Safety Code) and 410 IAC 16.2. The 2011 Physical Therapy addition was surveyed with Chapter 18, New Health Care Occupancies. This 2011 addition to the one story facility was determined to be of Type V (111) construction and	{K 000}					

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/04/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155502	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 10/02/2012
NAME OF PROVIDER OR SUPPLIER TRANSCENDENT HEALTHCARE OF OWENSVILLE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE HWY 165 W PO BOX 369 OWENSVILLE, IN 47665		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
{K 000}	<p>Continued From page 2</p> <p>was fully sprinklered. The Physical Therapy addition has a fire alarm system with smoke detection in the corridor and Physical Therapy area. The facility has a capacity of 68 and had a census of 59 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.</p> <p>All areas where residents have customary access were sprinklered and all areas providing facility services were sprinklered.</p>	{K 000}			